
## Fuel Oil Routine Fuel Oil Storage Tank Evaluation



Fuel Oil Routine Fuel Oil Storage Tank Evaluation — For above ground tanks.

## Routine Fuel Oil Storage Tank Evaluation – above ground tanks Revised May 2006

Name	*			
Address				
Town	State	Zip		
Telephone ( )				
Tank				
Tank securely mounted in flood prone are	as?	N/A	Yes	No
Any evidence of historic oil spills?			Yes	No
Tank checked for oil leaks?			Yes	No
Amount of oil in tank?				
Any water in tank?			Yes	No
If yes, how many inches?				3,555
Tank gauge in good condition?			Yes	No
Tank at least 5 feet from burner or other so	ources of fire or flame?		Yes	No
Evidence of external corrosion?			Yes	No
Unused openings properly plugged?			Yes	No
Comments:				
Fill Pipe				
In good condition?			Yes	No
Fill cap in place & in good condition?			Yes	No
Fill positioned to avoid buildup of water a	nd snow?		Yes	No
Fill properly identified?			Yes	No
Comments:				
S DI				
Vent Pipe			W	AT-
In good condition?			Yes Yes	No No
Vent cap in place & in good condition?  Vent free of obstructions?			Yes	No
Positioned to avoid buildup of water and s	now?		Yes	No
Comments:	now?		ies	NO
Oil lines				
Oil lines Working shutoff at tank?			Yes	No
All lines properly connected to tank and b	urnar?		Yes	No
Outside exposed lines insulated?	urner:	N/A	Yes	No
Comments:		IVA	1 65	140
Comments			0.00	6955
This tank is still acceptable for fuel delive	ry		Yes	No
Comments:				
Inspected by:	D	ate:		

PLEASE NOTE: The visual tank inspection performed was limited to the items inspected on the tank as noted on this inspection form, and does not cover any other area of the house or property, or parts of the tank system not visible. The inspection conducted and the results reported on this inspection Report represent the visible condition(s) of the tank present on the day of inspection only. This inspection should not be construed as an opinion or prediction of the condition of the tank in the future. Conditions involving the tank(s) may change in the future, and future inspections are recommended. If you notice a change in the condition of the tank, please contact your retail Oilheat company immediately.